

HA Plastic

ACCESS PANEL - COMBINED PRODUCT TEST CERTIFICATE

|      |          |             |         |     |
|------|----------|-------------|---------|-----|
| FIRE | ACOUSTIC | SMOKE       | THERMAL | AIR |
| —    | 20 dB    | 1.92 m³/m/h | —       | —   |



This certificate confirms the tested acoustic performance of the product below, commissioned by **Jupiter Blue Ltd.**

**20** dB

(f, Hz 100-3150)

ACOUSTIC REDUCTION

PRODUCT DESCRIPTION

HA 560×560

METHODOLOGY

Laboratory Measurement to BS EN ISO 10140-2 (Airborne Sound Insulation)

TEST CODE / REFERENCE

WYC389347/P008

REPORT NUMBER

BMT/WYC389347

DATE

27th September 2017

CERTIFIED BY

**Jupiter Blue Ltd**

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk

T 01423 874753

Mon-Thurs 8.30-5.00 · Fri 8.30-4.30

Registered in England & Wales · Company No 06411066

TEST LABORATORY

Exova (UK) Ltd, Chiltern House, Stocking Lane, Hughenden Valley, High Wycombe, HP14 4ND

This certificate confirms the tested smoke performance of the product below, commissioned by **Jupiter Blue Ltd.**

| CHAMBER          | LEAKAGE RATE AT 25 PA (M <sup>3</sup> /M/H) |
|------------------|---------------------------------------------|
| Positive Chamber | <b>2.66</b>                                 |
| Negative Chamber | <b>1.92</b>                                 |

|                                              |
|----------------------------------------------|
| PRODUCT DESCRIPTION                          |
| HA 560                                       |
| METHODOLOGY                                  |
| Laboratory Measurement to BS EN 1634-3: 2004 |
| TEST REFERENCE                               |
| WYC 389347/08                                |
| DATE                                         |
| 2nd September 2017                           |

**CERTIFIED BY**

**Jupiter Blue Ltd**

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk

T 01423 874753

Mon-Thurs 8.30-5.00 • Fri 8.30-4.30

Registered in England & Wales • Company No 06411066

**TEST LABORATORY**

Exova (UK) Ltd, Chiltern House, Stocking Lane, Hughenden Valley, High Wycombe, HP14 4ND