

ANTI-LIGATURE-FR

ACCESS PANEL - COMBINED PRODUCT TEST CERTIFICATE

FIRE	ACOUSTIC	SMOKE	THERMAL	AIR
122 min	36 dB	0.64 m ³ /m/h	—	—



This certificate confirms the tested fire performance of the product below, commissioned by **Jupiter Blue Ltd.**

122 minutes

FIRE DURATION

PRODUCT DESCRIPTION

ANTI-LIGATURE 1400×1200mm

METHODOLOGY

BS 476: Part 22: 1987

REPORT NUMBER

BTC 21674F

PANEL POSITION

Ceiling

DATE

19th March 2021

CERTIFIED BY

Jupiter Blue Ltd

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk

T 01423 874753

Mon–Thurs 8.30–5.00 • Fri 8.30–4.30

Registered in England & Wales • Company No 06411066

TEST LABORATORY

The Building Test Centre, British Gypsum, East Leake, Loughborough, Leics. LE12 6NP

This certificate confirms the tested acoustic performance of the product below, commissioned by **Jupiter Blue Ltd.**

36 dB

(f, Hz 100-3150)

ACOUSTIC REDUCTION

PRODUCT DESCRIPTION

BUDGET-FIREPAN

METHODOLOGY

Laboratory Measurement to BS EN ISO 717-1:1997

TEST CODE / REFERENCE

BTC 17782A

REPORT NUMBER

H17782DA

DATE

7th June 2012

CERTIFIED BY

Jupiter Blue Ltd

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk


T 01423 874753

Mon-Thurs 8.30-5.00 · Fri 8.30-4.30

Registered in England & Wales · Company No 06411066

TEST LABORATORY

The Building Test Centre, British Gypsum, East Leake, Loughborough, Leics. LE12 6NP



This certificate confirms the tested smoke performance of the product below, commissioned by **Jupiter Blue Ltd.**

CHAMBER	LEAKAGE RATE AT 25 PA (M ³ /M/H)
Positive Chamber	0.50
Negative Chamber	0.64

PRODUCT DESCRIPTION
ANTI-LIG 800×2050MM
METHODOLOGY
Laboratory Measurement to BS EN 1634-3: 2004
TEST REFERENCE
WYC438136/02
DATE
31st March 2021

CERTIFIED BY

Jupiter Blue Ltd

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk

T 01423 874753

Mon–Thurs 8.30–5.00 • Fri 8.30–4.30

Registered in England & Wales • Company No 06411066

TEST LABORATORY

Warringtonfire, Holmesfield Road, Warrington, WA1 2DS