

DUPLEX-SP-120 (Single)

ACCESS PANEL · COMBINED PRODUCT TEST CERTIFICATE

FIRE	ACOUSTIC	SMOKE	THERMAL	AIR
122 min	36 dB	1.54 m ³ /m/h	0.55 W/m ² K	—



This certificate confirms the tested fire performance of the product below, commissioned by **Jupiter Blue Ltd.**

122 minutes

FIRE DURATION

PRODUCT DESCRIPTION

DUPLEX-RISER-120 1200×600mm

METHODOLOGY

BS 476: Part 20: 1987 & BS 476: Part 22: 1987

REPORT NUMBER

BTC 21674F

PANEL POSITION

Wall

DATE

19th March 2021

CERTIFIED BY

Jupiter Blue Ltd

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk

T 01423 874753

Mon–Thurs 8.30–5.00 • Fri 8.30–4.30

Registered in England & Wales • Company No 06411066

TEST LABORATORY

The Building Test Centre, British Gypsum, East Leake, Loughborough, Leics. LE12 6NP

This certificate confirms the tested acoustic performance of the product below, commissioned by **Jupiter Blue Ltd.**

36 dB

(f, Hz 100-3150)

ACOUSTIC REDUCTION

PRODUCT DESCRIPTION

DUPLEX120-SP SINGLE DOOR

METHODOLOGY

Laboratory Measurement to BS EN ISO 10140-2 : 2010

TEST CODE / REFERENCE

WYC549811/Project 003

REPORT NUMBER

H17782DA

DATE

19th February 2025

CERTIFIED BY

Jupiter Blue Ltd

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk

T 01423 874753

Mon-Thurs 8.30-5.00 · Fri 8.30-4.30

Registered in England & Wales · Company No 06411066

TEST LABORATORY

WarringtonFire Ltd, Chiltern House, Stocking Lane, Hughenden Valley, HP14 4ND

This certificate confirms the tested thermal performance of the product below, commissioned by **Jupiter Blue Ltd.**

0.55 $\text{W/m}^2\text{K}$

U-VALUE

PRODUCT DESCRIPTION

DUPLEX-120-SP

TEST CODE

CODE

METHODOLOGY

BS EN ISO 6946

DATE

30th May 2025

CERTIFIED BY

Jupiter Blue Ltd

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk

T 01423 874753

Mon-Thurs 8.30-5.00 · Fri 8.30-4.30

Registered in England & Wales · Company No 06411066

TEST LABORATORY

Calculated in-house to BS EN ISO 6946 by Jupiter Blue Ltd.