

EMB

ACCESS PANEL - COMBINED PRODUCT TEST CERTIFICATE

FIRE	ACOUSTIC	SMOKE	THERMAL	AIR
—	—	—	0.35 W/m ² K	—



This certificate confirms the tested thermal performance of the product below, commissioned by **Jupiter Blue Ltd.**

0.35 W/m²K

U-VALUE

PRODUCT DESCRIPTION

External Electricity Meter Box

TEST CODE

EMB/C

METHODOLOGY

BS EN ISO 6946

DATE

12th May 2023

CERTIFIED BY

Jupiter Blue Ltd

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk

T 01423 874753

Mon-Thurs 8.30-5.00 · Fri 8.30-4.30

Registered in England & Wales · Company No 06411066

TEST LABORATORY

Calculated in-house to BS EN ISO 6946 by Jupiter Blue Ltd.