

Meter Overbox

ACCESS PANEL - COMBINED PRODUCT TEST CERTIFICATE

FIRE	ACOUSTIC	SMOKE	THERMAL	AIR
69 min	20 dB	—	—	—



This certificate confirms the tested fire performance of the product below, commissioned by **Jupiter Blue Ltd.**

69 minutes

FIRE DURATION

PRODUCT DESCRIPTION

FIRE-RATED-OVERBOX

METHODOLOGY

BS EN 1634-1: 2014 + A1: 2018

REPORT NUMBER

WF526564

PANEL POSITION

Ceiling

DATE

22th December 2022

CERTIFIED BY

Jupiter Blue Ltd

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk

T 01423 874753

Mon-Thurs 8.30-5.00 · Fri 8.30-4.30

Registered in England & Wales · Company No 06411066

TEST LABORATORY

WarringtonFire Ltd, Chiltern House, Stocking Lane, Hughenden Valley, HP14 4ND