

PD

LOFT HATCH • COMBINED PRODUCT TEST CERTIFICATE

FIRE	ACOUSTIC	SMOKE	THERMAL	AIR
—	20 dB	—	0.35 W/m ² K	3.95 m ³ /hr/m ²



This certificate confirms the tested acoustic performance of the product below, commissioned by **Jupiter Blue Ltd.**

20dB

(f, Hz 100-3150)

ACOUSTIC REDUCTION

PRODUCT DESCRIPTION

PD35

METHODOLOGY

Laboratory Measurement to BS EN ISO 10140-2 : 2010

TEST CODE / REFERENCE

WYC549811/Project 001

REPORT NUMBER

PD 35 Hatch

DATE

18th February 2025

CERTIFIED BY

Jupiter Blue Ltd

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk


T 01423 874753

Mon-Thurs 8.30-5.00 · Fri 8.30-4.30

Registered in England & Wales · Company No 06411066

TEST LABORATORY

Warringtonfire, Holmesfield Road, Warrington, WA1 2DS



This certificate confirms the tested thermal performance of the product below, commissioned by **Jupiter Blue Ltd.**

0.35 W/m²K

U-VALUE

PRODUCT DESCRIPTION

PD35

TEST CODE

PD35/C

METHODOLOGY

BS EN ISO 6946

DATE

12th May 2023

CERTIFIED BY

Jupiter Blue Ltd

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk

T 01423 874753

Mon-Thurs 8.30-5.00 · Fri 8.30-4.30

Registered in England & Wales · Company No 06411066

TEST LABORATORY

Calculated in-house to BS EN ISO 6946 by Jupiter Blue Ltd.

This certificate confirms the tested air performance of the product below, commissioned by **Jupiter Blue Ltd.**

DIRECTION	PRESSURE DIFF. (PA)	MAX AIR PERMEABILITY (M ³ /HR/M ²)
Infiltration (positive)	50	2.60
Exfiltration (negative)	50	3.95

PRODUCT DESCRIPTION

PD35 (with 'P' section gasket)

METHODOLOGY

Bespoke air permeability testing: BS EN 1026:2000 and BS EN 12207:2000, as per method statement PSR/MDW/M1352/07/1237 Revision 1.

REPORT NUMBER

PSR/R1861/07/1237/WEL

DATE

22nd August 2011

CERTIFIED BY

Jupiter Blue Ltd

Registered Office

Unit 86 Marston Moor Business Park,

Tockwith, YO26 7QF

E info@jupiterblue.co.uk

T 01423 874753

Mon-Thurs 8.30-5.00 · Fri 8.30-4.30

Registered in England & Wales · Company No 06411066

TEST LABORATORY

Wintech Engineering Ltd, Halesfield 2, Telford, Shropshire, TF7 4QH